

## Utilization of System KAN-therm Press for cooling systems filled with antifreeze solutions.

Hereby KAN Sp. z o.o. as a producer of System KAN-therm Press, consisting of polyethylene multilayer pipes PE-RT/Al/PE-RT and PE-Xc/Al/PE-Xc as well as fittings (made of PPSU plastic or brass, equipped with EPDM O-ring seals) connected together by means of radial press technique informs, that above mentioned installation system is suitable for creation of cooling systems, with operating pressure up to 10 bar and minimal operating temperature -10 °C.

It is allowed to fill such installation system with antifreeze agents based over ethylene or propylene glycols which maximal concentration is not exceeding 50%.

For maximum safety please contact Your local KAN Sales Manager to check possibility of utilization of specified liquids.

It is not allowed to fill such installation system with salty water or brines as well as any other chemical solutions without their acceptance by KAN-therm Press manufacturer on writing.

KAN Sp. z o.o. issues standard 10 year warranty for System KAN-therm Press elements utilized for creation of cooling systems implemented in accordance with above information as well as other standard technical guidelines given by the manufacturer.

Kind regards

Technical Adviser  
  
MSc. Marcin Kuryłonek

**KAN Sp. z o.o.**  
16-001 Białystok-Kleosin  
ul. Zdrojowa 51, tel. 0048 85 7499-200  
NIP 966-13-19-453



**KAN Sp. z o.o.**

ul. Zdrojowa 51, 16-001 Białystok-Kleosin, NIP: 9661319453, KRS: 0000187613  
tel. +48 85 74 99 200, fax +48 85 74 99 201, e-mail: [kan@kan-therm.com](mailto:kan@kan-therm.com)

[www.kan-therm.com](http://www.kan-therm.com)