

Vestone 10.09.2020

Object : declaration Blackfire UV resistance in compliance to ISO 4892-2.

We hereby declare that the UV resistance test on Blackfire product has arrived at 9000 hours today.

Test conditions

Black pannel STD 65°C

Irradiance at 340nm : 0,5W/m2

Chamber Temp :40°C

Rain :Yes

Relativ Humidity :50%

Rain /Dry :18'/102'

After this period the product is neither opaque nor whitened.


This duration ensures today a resistance of the product of about 7 years at a latitude of southern Europe (Spain, Italy, Greece, Bulgaria, Albania, countries of the ex Yugoslavia).

The test is still ongoing and will continue for the next months; at the end of the test we will inform you about the results obtained.

Best regards

Technical office

Eng. G. Vitali



VALSIR S.p.A. - Società a Socio Unico

Località Merlaro, 2 - 25078 Vestone (BS) - Italy

Tel. +39 0365 877.011 - Fax +39 0365 81268 - E-mail: valsir@valsir.it - **www.valsir.it**

Cap. Soc. €50.000.000 int. vers. - cod. fisc. e Reg. Imp. Brescia 02878210174

P.IVA 00700170988 - R.E.A. c.c.i.a.a. Bs 301171 - Mecc. Bs 001856

Soggetta all'attività di direzione e coordinamento da parte di SILMAR GROUP S.p.A.

C.F. 02075160172