



DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DV-8601BS0115

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas and water supply <i>Produkte der Gas- und Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Fusion Group Ltd. Smeckley Wood Close Chesterfield Trading Estate, GB- Chesterfield Derbyshire S41 9PZ
Distributor <i>Vertreiber</i>	Fusion Group Ltd. Smeckley Wood Close Chesterfield Trading Estate, GB- Chesterfield Derbyshire S41 9PZ
Product Category <i>Produktart</i>	Plastic fittings and compression fittings: PE-HD electro fusion fitting, size group 1 (8603)
Product description <i>Produktbezeichnung</i>	electro fusion fittings made of PE-HD (PE 100) for the gas and drinking water supply
Model <i>Modell</i>	Fusamatic
Test reports <i>Prüfberichte</i>	Laboratory control test: from 15.04.2025 (KIW) Mechanical test: DKW/SR110216 from 17.02.2011 (KIW) Type testing: KL 3784-1-3 from 01.03.2006 (KIW)
Test basis <i>Prüfgrundlagen</i>	DVGW GW 335-B2 (01.09.2004) DVGW GW 335-B2/B1 (01.02.2013)

Date of Expiry / File No. 15.03.2027 / 26-0420-WNV
Ablaufdatum / Aktenzeichen

70028-04-A-DE

06.05.2026 Le A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvwg-cert.com
www.dvlgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Fusamatic	Nominal diameter: 20 mm	coupler, end cap, 45°-elbow, 90°-elbow, equal tee, reducer
Fusamatic	Nominal diameter: 25 mm	coupler, end cap, 45°-elbow, 90°-elbow, equal tee, reducer
Fusamatic	Nominal diameter: 32 mm	coupler, end cap, 45°-elbow, 90°-elbow, equal tee, reducer
Fusamatic	Nominal diameter: 40 mm	coupler, end cap, 45°-elbow, 90°-elbow, equal tee, reducer, saddle
Fusamatic	Nominal diameter: 50 mm	coupler, end cap, 45°-elbow, 90°-elbow, equal tee, reducer, saddle
Fusamatic	Nominal diameter: 63 mm	coupler, end cap, 45°-elbow, 90°-elbow, equal tee, reducer, saddle

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

rated pressure gas PN 6
 rated pressure water PN 16
 SDR 11

Suitability for drinking water hygiene is verified with a "Hygiene confirmation of conformity" in accordance with the currently valid legal basis.

DVGW
CERT