



QUALITY CERTIFICATE TYPE 2.2 (UNE-EN 10204)

FULL BORE BALL VALVE, REF. 3031

MATERIAL:

CW602N BRASS WITH THERMAL TREATMENT
DZR ANTICORROSION BRASS, RESISTANCE TO DEZINCIFICATION
ACCORDING EN-ISO 6509
FULL BORE BALL VALVE
NICKEL PLATED FINISHING SURFACE
GAS (BSP) THREADED FEMALE-FEMALE (F-F) ENDS ACCORDING TO ISO 228/1.
WORKING BY MEANS OF AISI 304 STAINLESS STEEL LEVER HANDLE.
PTFE SEATS
DOUBLE NBR O-RING

CHARACTERISTICS:

NOMINAL PRESSURE: 25 bar
MAX. WORKING TEMPERATURE: +110° C

TEST RESULTS:

SHELL TEST: 38 bar (Hydraulic)
BODY LEAKAGE TEST: 6 bar (Pneumatic)
SEATS LEAKAGE TEST: 6 bar (Pneumatic)
TESTING RESULTS ARE IN ACCORDANCE TO THE PARTS A.2.3, A.3.3
AND A.4.3
ACCEPTANCE CRITERIA FROM UNE-EN 12266-1 STANDARD.

GENEBRE CERTIFY:

ABOVE DESCRIBED PRODUCTS ACCOMPLISH WITH THE INDICATED QUALITY FEATURES.

MATERIALS ACCOMPLISH WITH THE INDICATED QUALITY FEATURES.

MATERIALS HAVE BEEN MADE AND TESTED ACCORDING TO THE REQUIREMENTS ESTABLISHED IN THE SUITABLE MANUFACTURING AND CONTROL STANDARDS.

GENEBRE, S.A. QUALITY DEPARTMENT
AVENIDA DE JOAN CARLES I, 46 – 48
08908 L'HOSPITALET DE LLOBREGAT
BARCELONA (SPAIN)