

Declaration of performance nr 2/2023

Termojet Sp. z o.o., Wolnosci Str. 191, 41-800 Zabrze, Poland

NIP: 6272474666

Grupa TermoJet (Sofiyivka, Sofiyivka Montazh), Kiev, Sofiyivska

Borschagivka, Kyivska Str. 3, Ukraine

We hereby declare that the products: thermostatic mixing valves TMV DN20 and DN25 models as below: TMV 121, TMV 131, TMV 231, TMV 122, TMV 132, TMV 232, - meet the requirements of the national technical specification:
- Poland Product standard: PN-EN 1111:2017 Sanitary fittings. Thermostatic taps (PN 10). General Technical Specifications.

Name of the accredited certification body, accreditation number and national certificate number or name accredited laboratory and accreditation number: not applicable.

- National technical assessment: not applicable.

- Technical Assessment Body/National Technical Assessment Body: not applicable.

Name of the accredited certification body, accreditation number and certificate number: not applicable.

National system used to assess and verify constancy of performance: 4

Declared performance properties:

Type	Diameter	KVS, m3/h	Temp., °C
TMV122	DN20	1,6	35-60
TMV132	DN25	1,6	35-60
TMV232	DN25	2,5	35-60
TMV121	DN20	1,6	20-43
TMV131	DN25	1,6	20-43
TMV231	DN25	2,5	20-43

The above-mentioned products are intended for use in heating system and for sanitary water system with the following parameters: T max = 95°C and P max = 10 bar. Other parameters and dimensions available in catalog cards and manuals.

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Zabrze 19.01.2023

Oleksandr Kutsevych

